

ENVIRONMENT PROTECTION LICENCE 3035

MARCH 2019 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
15-MAR	<0.010	7	65	<0.010	0.2	5.8	<5	7.7	0.23	22	N
19-MAR	<0.010	7	35	<0.010	0.2	4.7	5	6.98	0.1	29	N
27-MAR	<0.010	3	60	<0.010	<0.1	3.8	<5	7.47	0.1	41	N