

ENVIRONMENT PROTECTION LICENCE 3035

NOVEMBER 2019 Surface Water Quality Monitoring

LIMITS

ANALYTE	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS
Units	µg/L	mg/L	Hazen	µg/L	mg/L	mg/L	mg/L	pH	mg/L	mg/L
100 percentile concentration limit	0.3	20	160	0.3	0.5	10	10	6.5 - 8.5	0.3	50
50 percentile concentration limit			80							
Frequency of Sampling	Weekly during any discharge									
Location of Sampling	V-Notch Weir Identification Point No. 1									

RESULTS

Date	Aldrin	BOD	Colour	Dieldrin	MBAS	Total N	Oil & Grease	pH	Total P	TSS	Exceedance Y/N
28/11/2019	<0.010	2	30	<0.010	0.1	1.7	<5	8.05	0.05	40	N

No further monitoring conducted during November 2019 due to no flow/no discharge from site